



Portable Appliance Test Certificate.

This Certificate Complies with the Following Regulations.

Health and Safety at work Act 1974 (HSWA).

Electricity at Work Regulations 1989 (EAWR).

Management of Health and Safety at Work Regulations 1999 amended 2003 (MHSWR)

Provision and Use of Work Equipment Regulations 1998 amended 2002 (PUWER)

This is to Certify that a Visual Inspection and Electrical Test of the
Portable and Fixed Electrical Equipment Owned or Managed by :-

The Big Party Band
1 Longwood Hall
Longwood Avenue
Bingley
BD16 2RX

Was carried Out By :-

Stuart Smith of Emerald PAT Testing Limited
on
18th October 2014

The Inspection and Tests were carried out in accordance with the above legislation,
in accordance with the guidance laid down by the Institution of Electrical Engineers
in their 4th Edition Code of Practice for In Service Inspection and Testing of
Electrical Equipment.

The Log and Failed Log which is provide with this Certificate details the
Appliances Tested and the Results that were obtained.


Results Found

Number of Appliances Tested :-	64
Number of Appliances Passed :-	64
Details of Appliances Failed :-	See Attached Log for Details
Certificate Reference :-	18-10-14-01
Suggested Re-Test Date :-	18th October 2016

Signed by Engineer.



S W Smith
Stuart Smith



Portable Appliance Log 1.

0

Tel: Leeds 0113 3141514 - Wakefield 01924 820148 - Mob:0757 0835583

Emerald PAT Testing Ltd



Email: info@emerald-pat-testing.co.uk
 Web: <http://www.emerald-pat-testing.co.uk>

Emerald PAT Testing Ltd, Unit 39g, Springfield,
 Bagley Lane, Farsley, Leeds. LS28 5LY

Results of Tests Carried Out											
Log No	Appliance Description	Appliance Location	Class 1 or 2	Visual Inspection	Earth Ohms	Insulation Mohms	Leakage mA	Comments	PASS FAIL	Test No	
1	psu	studio	2	PASS	n/a	>19.99	0.10		PASS	1	
2	base bin	studio	1	PASS	0.06	>19.99	0.10		PASS	2	
3	lead	studio	1	PASS	0.06	>19.99	good		PASS	3	
4	psu	studio	2	PASS	n/a	>19.99	0.10		PASS	4	
5	lead	studio	1	PASS	0.06	>19.99	good		PASS	5	
6	extension	studio	1	PASS	0.16	>19.99	good		PASS	6	
7	adaapter	studio	1	PASS	0.01	>19.99	good		PASS	7	
8	lead	studio	1	PASS	0.08	>19.99	good		PASS	8	
9	adaapter	studio	1	PASS	0.08	>19.99	good		PASS	9	
10	extension	studio	1	PASS	0.07	>19.99	good		PASS	10	
11	extension	studio	1	PASS	0.15	>19.99	good		PASS	11	
12	extension	studio	1	PASS	0.07	>19.99	good		PASS	12	
13	extension	studio	1	PASS	0.24	>19.99	good		PASS	13	
14	extension	studio	1	PASS	0.17	>19.99	good		PASS	14	
15	extension	studio	1	PASS	0.08	>19.99	good		PASS	15	
16	smoke machine	studio	1	PASS	0.08	>19.99	0.10		PASS	16	
17	smoke remote	studio	1	PASS	0.08	>19.99	0.10		PASS	17	
18	mixer desk	studio	1	PASS	n/a	>19.99	0.10	no earth	PASS	18	
19	guitar amp	studio	1	PASS	0.15	>19.99	0.10		PASS	19	
20	lead	studio	1	PASS	0.07	>19.99	good		PASS	20	
21	extension	studio	1	PASS	0.08	>19.99	good		PASS	21	
22	pedal board extension	studio	1	PASS	0.05	>19.99	good		PASS	22	
23	pedal board sound lab	studio	1	PASS	0.05	>19.99	good		PASS	23	
24	pedal board sr40 psu	studio	2	PASS	n/a	>19.99	0.10		PASS	24	
25	pedal board psu	studio	2	PASS	n/a	>19.99	0.10		PASS	25	
26	acme light	studio	1	PASS	0.14	>19.99	0.10		PASS	26	
27	lead	studio	1	PASS	0.06	>19.99	good		PASS	27	
28	keyboard amp	studio	1	PASS	0.07	>19.99	0.10		PASS	28	
29	wedge monitor	studio	1	PASS	0.20	>19.99	0.10		PASS	29	
30	lead	studio	1	PASS	0.08	>19.99	good		PASS	30	
31	base combo	studio	1	PASS	0.09	>19.99	0.29		PASS	31	
32	lead	studio	1	PASS	0.08	>19.99	good		PASS	32	
33	extension	studio	1	PASS	0.47	>19.99	good		PASS	33	
34	sunstrip light	studio	1	PASS	0.15	>19.99	0.10		PASS	34	
35	psu	studio	2	PASS	n/a	>19.99	0.10		PASS	35	
36	parcan 56	studio	1	PASS	0.10	>19.99	0.14		PASS	36	
37	parcan 56	studio	1	PASS	0.10	>19.99	0.14		PASS	37	
38	parcan 56	studio	1	PASS	0.20	>19.99	0.10		PASS	38	
39	parcan 56	studio	1	PASS	0.16	>19.99	0.10		PASS	39	
40	parcan 56	studio	1	PASS	0.09	>19.99	0.10		PASS	40	
41	parcan 56	studio	1	PASS	0.17	>19.99	0.10		PASS	41	
42	parcan 56	studio	1	PASS	0.13	>19.99	0.10		PASS	42	
43	parcan 56	studio	1	PASS	0.14	>19.99	0.10		PASS	43	
44	parcan power	studio	1	PASS	0.18	>19.99	0.44		PASS	44	
45	parcan lead	studio	1	PASS	0.10	>19.99	0.10		PASS	45	
46	parcan lead	studio	1	PASS	0.10	>19.99	0.10		PASS	46	
47	extension	studio	1	PASS	0.07	>19.99	good		PASS	47	
48	keyboard psu	studio	2	PASS	n/a	>19.99	0.10		PASS	48	
49	keyboard psu	studio	2	PASS	n/a	>19.99	0.10		PASS	49	
50	psu	studio	2	PASS	n/a	>19.99	0.10		PASS	50	
51	pa cab speaker	studio	1	PASS	0.08	>19.99	0.29		PASS	51	
52	lead	studio	1	PASS	0.08	>19.99	good		PASS	52	
53	pa cab speaker	studio	1	PASS	0.13	>19.99	0.10		PASS	53	
Test Engineer Sign - S W Smith				Test Engineer Name - Stuart Smith					18th Oct 2014		

